



## **NOTES:**

- 1. USE #8 AWG STRANDED COPPER WIRE WITH HMWPE INSULATION FOR JOINT BONDS ON PIPE SIZES 12 INCHES IN DIAMETER AND SMALLER AND USE #4 AWG STRANDED COPPER WIRE WITH HMWPE INSULATION FOR JOINT BONDS ON PIPE SIZES LARGER THAN 12 INCHES IN DIAMETER.
- 2. JOINT BONDS ARE NOT REQUIRED AT MECHANICAL JOINTS WHERE MECHANICAL JOINT RESTRAINT GLANDS HAVE BEEN INSTALLED
- 3. PIPE AND FITTING GASKETS ARE TO BE COVERED AND PROTECTED FROM DAMAGE WHEN INSTALLING JOINT BONDS

## CITY OF ROCHESTER

JOINT BOND FOR METALLIC WATER MAIN PIPE/FITTING

ISSUED	1-13-06	NON-STANDARD
REVISED	9-16-13	DWG.NO.S962-1