




ELEVATION

DIMENSIONS AND CLEARANCES					
WATER METER TYPE	WATER METER SIZE (INCHES)	LENGTH WATER METER "A" (INCHES)	MINIMUM DIMENSIONS		
			MINIMUM LENGTH STRAIGHT PIPE "B" (INCHES)	MINIMUM LENGTH STRAIGHT PIPE "C" (INCHES)	MINIMUM CLEARANCE PIPE TO WALL (INCHES)
COMPOUND	3"	17"	20"	18"	24"
	4"	20"	20"	18"	24"
	6"	24"	30"	18"	24"
TURBO	6"	18"	30"	18"	24"
	8"	20"	40"	18"	24"
	10"	26"	50"	24"	30"
FIRE SERIES ASSEMBLY	6"	45"***	24"	18"	36"
	8"	53"***	24"	18"	36"
	10"	68"***	24"	24"	42"

*** METER LENGTH INCLUDES STRAINER FOR FIRE SERIES ASSEMBLIES ONLY

NOTES:

1. IF WATER METER SIZE IS SMALLER THAN SIZE OF WATER SERVICE, PROVIDE ADEQUATE CLEARANCE FOR FUTURE INSTALLATION OF FULL SIZED METER.
2. A BACKFLOW PREVENTION DEVICE IS REQUIRED ON ALL DOMESTIC WATER SERVICES 1½" AND LARGER.
3. PIPE AND APPURTENANCES ARE TO BE ADEQUATELY RESTRAINED, BRACED AND SUPPORTED. ALL WORK AND MATERIALS SHALL BE IN CONFORMANCE WITH APPLICABLE FEDERAL, STATE AND LOCAL PLUMBING CODES.

CITY OF ROCHESTER		
TYPICAL INDOOR		
INSTALLATION OF		
DOMESTIC WATER METER		
3 INCH TO 10 INCH		
ISSUED	8-8-11	NON-STANDARD DWG.NO.S970-6
REVISED		