



NOTES:

1. SERVICE SADDLE IS REQUIRED FOR CAST/DUCTILE IRON WATER MAIN THAT IS LESS THAN 12 INCHES IN DIAMETER AND FOR ALL PLASTIC WATER MAIN.
2. FOR CAST/DUCTILE IRON WATER MAIN, USE 1 INCH AWWA INLET x 1 1/4 INCH MPT OUTLET PLUG STYLE CORPORATION STOP. TAP WATER MAIN USING 1 INCH MINIMUM DIAMETER DRILL BIT.
3. FOR PLASTIC WATER MAIN, USE 1 1/2 INCH BALL VALVE CORPORATION STOP WITH 1 1/2 INCH AWWA INLET x 1 1/2 INCH FPT OUTLET. TAP WATER MAIN USING 1 3/8 INCH MINIMUM DIAMETER PVC SHELL CUTTERS. INSTALL 1 1/2 INCH MPT x 1 1/4 INCH FPT BRASS BUSHING ON CORPORATION STOP OUTLET.
4. FOR CAST/DUCTILE IRON WATER MAIN, USE 1 INCH BALL VALVE WITH 1 1/4 INCH FPT INLET AND OUTLET. FOR PLASTIC WATER MAIN, USE 1 INCH BALL VALVE WITH 1 1/4 INCH MPT INLET AND 1 1/4 INCH FPT OUTLET.
5. WATER SERVICE CARD IS TO BE COMPLETED FOR EACH PITOMETER TAP. SEE DETAIL R913-3.

CITY OF ROCHESTER		
PITOMETER TAP		
ISSUED	3-10-99	NON-STANDARD DWG.NO.S911-1
REVISED	7-25-13	