



NOTES:

1. MINIMUM WIDTH OF ACCESS RAMP IS 4 FEET.
2. SURFACE OF ACCESS RAMP TO BE FIRM, STABLE AND SLIP-RESISTANT. TEXTURE SURFACE WITH COARSE BROOM RUNNING TRANSVERSE TO SLOPE OF ACCESS RAMP.
3. ENTIRE AREA OF ACCESS RAMP AND LANDING PAD TO BE 7 INCH THICK CONCRETE.

CITY OF ROCHESTER		
<p>SIDEWALK ACCESS RAMP TYPE I</p>		
ISSUED	3-21-94	NON-STANDARD DWG.NO.S608-38
REVISED	7-1-17	