



OTHER PAVED SURFACES
 STRUCTURES AND
 APPURTENANCES

LAWN

NOTES:

1. MINIMUM CLEAR WIDTH FOR SIDEWALK IS 5 FEET AS MEASURED FROM BACK EDGE OF CURB OR CONCRETE GUTTER.
2. CROSS SLOPE OF SIDEWALK TO BE 1.50%.
3. SURFACE TO BE FIRM, STABLE AND SLIP-RESISTANT.
4. SIDEWALK ACCESS RAMP AND LANDING PAD TO BE 7 INCH THICK CLASS K CONCRETE.
5. PROVIDE 1/2 INCH WIDE EXPANSION JOINT BETWEEN NEW CONCRETE CONSTRUCTION AND OTHER PAVED SURFACES, STRUCTURES AND APPURTENANCES.
6. EXPANSION JOINT: 1/2 INCH WIDE PREMOULDED EXPANSION JOINT MATERIAL, SEAL WITH CAULKING SEALANT 1/2 INCH WIDE 5/8 INCH DEEP.
7. SIDEWALK SURFACE, GRADE AND CROSS SLOPE ARE TO BE MAINTAINED ACROSS DRIVEWAYS.

CITY OF ROCHESTER

PERVIOUS CONCRETE SIDEWALK AND DRIVEWAY

ISSUED	12-1-15	NON-STANDARD DWG.NO.S608-39
REVISED	7-1-17	