

- 1. CURB IS TO BE NYSDOT TYPE C CURB OR APPROVED EQUIVALENT WITH OVERALL TOP WIDTH AND REVEAL AS REQUIRED IN CONTRACT DOCUMENTS.
- 2. APPLY TACK COAT TO UNEXPOSED FACE OF CURB AND BETWEEN ALL LIFTS OF HMA COURSES.
- 3. HMA COURSES TO BE EITHER 60, 70 OR 80 SERIES COMPACTION AS REQUIRED IN CONTRACT DOCUMENTS.
- 4. SEAL ALL TOP COURSE JOINTS WITH ASPHALT PAVEMENT JOINT ADHESIVE IN ACCORDANCE WITH NYSDOT SECTION 418 ASPHALT PAVEMENT JOINT ADHESIVE.
- 5. BACKFILL EXCAVATION BEHIND NEW CURB WITH APPROVED EXCAVATED RE-USE ON-SITE MATERIAL TOPPED WITH 4 INCHES OFF-SITE LAWN TOPSOIL IN ACCORDANCE WITH NYSDOT SECTION 713-01 TOPSOIL.
- 6. UNDERDRAIN PIPE AND FILTER MATERIAL TO BE INSTALLED AS INDICATED IN CONSTRUCTION DOCUMENTS. TYPICAL DEPTH OF UNDERDRAIN PIPE TO BE CHANGED AS NECESSARY TO MAINTAIN POSITIVE DRAINAGE TO DRAINAGE STRUCTURES.
- 7. SEE DETAIL R609-1 FOR CURB INSTALLATION.

OF ROCHESTER CITY

STONE CURB REPLACEMENT AT CONCRETE GUTTER ASPHALT BASE

ISSUED 12-30-11 NON-STANDARD REVISED 1-19-21 DWG.NO.S609-18