



NOTES:

1. USE CLASS A CONCRETE FOR CONVENTIONALLY FORMED CONCRETE CURB - CLASS J CONCRETE FOR MACHINE FORMED CONCRETE CURB.
2. BOTTOM OF CONCRETE CURB AND CONCRETE BASE TO BE AT SAME ELEVATION.
3. EXPANSION JOINTS TO BE 3/4 INCH WIDE SPACED EVERY 20 FEET AND AT ALL IMMOVABLE OBJECTS. FILL JOINTS WITH PREMOLDED RESILIENT JOINT FILLER MATERIAL.
4. CURB REVEAL FOR HEADER CURB AT DRIVEWAY APRONS IS 1 1/2 INCHES, AT SIDEWALK ACCESS RAMPS 0 INCHES.
5. TACK COAT TO BE APPLIED BETWEEN ALL LIFTS OF HMA COURSES AND ON TOP OF CONCRETE BASE.
6. PAVEMENT SEAMS TO BE SEALED WITH BITUMINOUS SEALER IN ACCORDANCE WITH NYSDOT MATERIAL DESIGNATION 702-0700.
7. UNDERDRAIN PIPE AND FILTER MATERIAL TO BE INSTALLED AS INDICATED IN CONSTRUCTION DOCUMENTS. TYPICAL DEPTH OF UNDERDRAIN PIPE TO BE CHANGED AS NECESSARY TO MAINTAIN POSITIVE DRAINAGE TO DRAINAGE STRUCTURES.

CITY OF ROCHESTER		
CONCRETE CURB REPLACEMENT		
ISSUED	9-2-91	STANDARD
REVISED	2-19-21	DWG.NO.R609-6