

NOTES:

- 1.BOX AND COVER TO BE POLYMER CONCRETE, STRAIGHT WALLED WITH OPEN BOTTOM, IN ACCORDANCE WITH QUAZITE STYLE PG BY HUBBELL INC, OR APPROVED EQUIVALENT. SURFACE TO BE SKID RESISTANT. UNIT TO BE RATED FOR ANSI/SCTE 77 2017 TIER 22. ADDITIONAL HARDWARE TO BE STAINLESS STEEL.
- 2.PLACE AND COMPACT 3 TO 6 INCHES OF SAND OR GRAVEL IN BOTTOM OF EXCAVATION. SETTLE BOX FIRMLY ON TOP OF COMPACTED MATERIAL.
- 3.USE CONDUIT EXTENSION(S) AND COUPLING(S) TO EXTEND CONDUIT INTO AND MINIMUM OF 6 INCHES ABOVE BOTTOM OF BOX. CAP OPEN END OF CONDUIT WITH APPROPRIATE FITTINGS.
- 4.AFTER CONDUIT HAS BEEN INSTALLED AND CAPPED, PLACE 6 INCHES OF LOOSE UNCOMPACTED SUBBASE COURSE TYPE 1 MATERIAL IN BOTTOM OF BOX AND ENCOMPASSING CONDUIT.

CITY OF ROCHESTER

POLYMER CONCRETE HANDHOLE

ISSUED 12-1-22 NON-STANDARD REVISED DWG.NO.S671-19