



NOTES:

1. PUMPER CONNECTION IS TO FACE PAVEMENT.
2. MECHANICAL JOINT OFFSET OR HYDRANT EXTENSION KIT CAN BE USED TO SET HYDRANT AT PROPER ELEVATION.
3. WHEN GROUND WATER IS ENCOUNTERED IN TRENCH, IF APPROVED OF BY CITY, HYDRANT WEEP HOLES MAY BE PLUGGED AND STONE DRAIN OMITTED. CONTRACTOR IS TO NOTIFY WATER BUREAU IN WRITING WHEN WEEP HOLES HAVE BEEN PLUGGED
4. HYDRANT MARKERS TO BE FURNISHED AND INSTALLED BY WATER BUREAU UNLESS OTHERWISE NOTED ON PLANS OR AS DIRECTED BY PROJECT MANAGER.

CITY OF ROCHESTER		
HYDRANT AT EXISTING BRANCH		
ISSUED	9-2-91	STD. DWG.
REVISED	1-26-17	NO. R917-2